



# Life Science Laboratories, Inc.

Dana L. Harris  
Wellsville Water Treatment Plant  
111 W State St.  
Wellsville, NY 14895

Phone: (585) 593-3333  
FAX: (585) 593-5864

## Laboratory Analysis Report Prepared For Wellsville Water Treatment Plant

LSL Project ID: 2001615

Receive Date/Time: 02/04/20 12:55

Life Science Laboratories, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose. By the Client's acceptance and/or use of this report, the Client agrees that LSL is hereby released from any and all liabilities, claims, damages or causes of action affecting or which may affect the Client as regards to the results contained in this report. The Client further agrees that the only remedy available to the Client in the event of proven non-conformity with the above warranty shall be for LSL to re-perform the analytical test(s) at no charge to the Client. The data contained in this report are for the exclusive use of the Client to whom it is addressed, and the release of these data to any other party, or the use of the name, trademark or service mark of Life Science Laboratories, Inc. especially for the use of advertising to the general public, is strictly prohibited without express prior written consent of Life Science Laboratories, Inc. This report may only be reproduced in its entirety. No partial duplication is allowed. The Chain of Custody and the Sample Receipt documents submitted with these samples are considered by LSL to be an appendix of this report and may contain data qualifiers and specific information that pertains to the samples included in this report. The analytical result(s) in this report are only representative of the sample(s) submitted for analysis. LSL makes no claim of a sample's representativeness, or integrity, if sampling was not performed by LSL personnel.

LSL Central Lab  
5854 Butternut Drive  
East Syracuse, NY 13057  
Tel. (315) 445-1900  
Fax (315) 445-1104  
NYS DOH ELAP #10248

LSL North Lab  
131 St. Lawrence Avenue  
Waddington, NY 13694  
Tel. (315) 388-4476  
Fax (315) 388-4061  
NYS DOH ELAP #10900

LSL Finger Lakes Lab  
16 N. Main St., PO Box  
424  
Wayland, NY 14572  
Tel. (585) 213-4090  
Fax (585) 213-4192  
NYS DOH ELAP

LSL Southern Tier Office  
Cuba, NY  
Tel. (585) 209-4032

LSL MidLakes Office  
Canandaigua, NY  
Tel. (585) 728-3320

This report was reviewed by:

  
Kristin E. Carpenter, Quality Staff

Date: 02/04/20



