

*Annual Drinking Water Quality Report for 2019
Village of Wellsville Water
111 W. State St.
Wellsville, NY 14895
Public Water Supply ID# NY 0200327*

INTRODUCTION

To comply with State regulations, the Wellsville Water Department, will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. Last year, we conducted tests for over 80 contaminants. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact Dana Harris, water plant supervisor at (585) 593-3333 or dana@wellsvillewater.com . We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled village board meetings which are held the 2nd and 4th Monday of each month at 7:00 pm @ 23 North Main St., Wellsville. You may also view our website at: www.wellsvillewater.com .

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the number of certain contaminants in water provided by public water systems. The State Health Departments and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water source is the Genesee River. The water is drawn from the river at our intake south of the treatment plant. During 2019, our system did not experience any restriction of our water source. The water is pumped from our intake to the treatment plant. After filtration, disinfection, pH adjustment, fluoridation, and corrosion control treatment, the water is then pumped to our (2) two million-gallon reservoirs. The water then flows to our consumers.

The New York State Department of Health has completed a source water assessment for this water system. The final report hasn't been published yet. When this becomes available, you may call (585) 593-3333 or dana@wellsvillewater.com for a copy and it will be posted on our website.

FACTS AND FIGURES

Our water system serves 5700 people through 2300 service connections. The total water produced in 2019 was 235 million gallons. The daily average water pumped into the system was 642,519 gallons. Our highest single day was 1,344,446 gallons. The amount of water delivered to customers was 150 million gallons. This leaves an unaccounted-for total of 128 million gallons (54% of the total amount produced). This water was used to flush mains, fight fires and leakage.

In 2019, water customers were charged \$0.57 per unit of water (1-unit equals 748 gallons) for 1 to 3 units. \$3.83 for 4 to 50 units. \$2.64 for 51 to 100 units. \$2.37 for 101 to 150 units. \$1.38 for over 150 units. Plus, a monthly service charge of \$16.00. For a more detailed explanation of our billing rates: <http://wellsvillewater.com/water-rates/>

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, turbidity, inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, total trihalomethanes, halo acetic acids, radiological and synthetic organic compounds.

The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old. For more detailed testing results, please visit our website for the latest sampling results at: <http://wellsvillewater.com/lab-results/>

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Allegany County Health Department at (585) 268-9250

Table of Detected Contaminants

Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg/Max) (Range)		Unit Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
Microbiological Contaminants								
Turbidity ²	No	Daily	High 0.23	Range 0.03 – 0.23	NTU	n/a	TT 0.3	Soil runoff
Radiological Contaminants								
Uranium	No	06/15/2016	0.056		ug/l	0	30	Erosion of natural deposits
Gross Alpha	No	06/15/2016	-0.128		pCi/L	0	15	Erosion of natural deposits
Gross Beta	No	06/15/2016	0.5777		pCi/L	0	MCL = 4 mrem/yr	Decay of natural deposits and man-made emissions.
Radium 228	No	06/15/2016	1.59		pCi/L	0	MCL = 5	Erosion of natural deposits
Inorganic Contaminants								
Barium	No	01/14/2019	0.030		mg/l	2	MCL = 2	Discharge of drilling wastes, metal refineries, natural deposits.
Chloride	No	Daily	High 23.8	Range 3.6 – 23.8	mg/l	n/a	MCL = 250	Naturally occurring or road salt contamination.
Copper ³	No	07/10/2019	Average 0.139	Range 0.035-0.280	mg/l	1.3	AL = 1.3	Corrosion of galvanized pipes, natural deposits.
Fluoride	No	Daily	Average 0.66	Range 0.38 – 1.04	mg/l	n/a	MCL = 2.2	Natural deposits, water additive that promotes strong teeth.
Lead ⁴	No	07/10/2019	Average 0.0014	Range nd-0.0021	mg/l	0	AL = 0.015	Corrosion of household plumbing systems, natural deposits
Nitrate	No	01/14/2019	1.5		mg/l	10	MCL = 10	Runoff from fertilizer use.
Sodium	No	01/14/2019	6.6		mg/l	n/a	n/a	Naturally occurring.
Disinfection Byproducts								
HAA5 ⁵	No	2019 Quarterly	Average 36.0	Range 17.0 – 48.0	ug/l	n/a	60	Byproduct of drinking water chlorination.
TTHM ⁶	No	2019 Quarterly	Average 56.0	Range 27.0 – 91.0	ug/l	n/a	80	Byproduct of drinking water chlorination.
Total Organic Compounds								
Entry Point ⁷	No	2019 Quarterly	Average 1.45	Range 1.40-1.50	mg/l	n/a	TT = 35% removal	Disinfection byproduct precursor.
Source ⁷	No	2019 Quarterly	Average 2.85	Range 2.2-3.6	mg/l	n/a	n/a	Disinfection byproduct precursor.

1 – A violation occurs in systems collecting less than 40 samples per month when two or more samples are total coliform positive.

2 – Turbidity is a measure of the cloudiness of the water. We test it because it is a good indicator of the effectiveness of our filtration system. Our highest single turbidity measurement 0.23 for the year occurred on 12/11/2019. State regulations require that turbidity must always be below 1 NTU. The regulations require that 95% of the turbidity samples collected have measurements below 0.3 NTU. 100% of our samples met this turbidity performance standard.

3 – The level presented represents the 90th percentile of the 20 sites sampled. The action level for copper was not exceeded at any of the sites tested.

4 – The level presented represents the 90th percentile of the 20 sites sampled. The action level for lead was not exceeded at any of the sites tested.

5 – HAA5's (mono-, di-, & trichloroacetic acid, and mono-, & dibromoacetic acid) The level presented represents the annual average from both testing sites.

6 – TTHM's (chloroform, bromodichloromethane, dibromochloromethane and bromoform) The level presented represents the annual average from both testing sites.

7 – The level presented represents the annual average.

Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Nephelometric Turbidity Unit (NTU): A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Milligrams per liter (mg/L): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Picocuries per liter (pCi/L): A measure of the radioactivity in water.

Millirems per year (mrem/yr): A measure of radiation absorbed by the body.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

WHAT DOES THIS INFORMATION MEAN?

As you can see from the table of detected contaminants, our system had no violations.

We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below New York State requirements.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2019, our system was in compliance with applicable State drinking water operating, monitoring and reporting requirements.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

INFORMATION ON FLUORIDE ADDITION

Our system is one of the many drinking water systems in New York State that provides drinking water with a controlled, low level of fluoride for consumer dental health protection. According to the United States Centers for Disease Control, fluoride is very effective in preventing cavities when present in drinking water at a properly controlled level. To ensure that the fluoride supplement in your water provides optimal dental protection, we monitor fluoride levels daily to make sure fluoride is maintained at a target level of 0.7 mg/. During 2019 monitoring showed that fluoride levels in your water were within 0.1 mg/l of the target level for 83% of the time. None of the monitoring results showed fluoride at levels that approach the 2.2 mg/l MCL for fluoride.

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are several reasons why it is important to conserve water:

- ◆ Saving water saves energy and some of the costs associated with both necessities of life;
- ◆ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ◆ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential firefighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ◆ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ◆ Turn off the tap when brushing your teeth.
- ◆ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- ◆ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.
- ◆ Use your water meter to detect hidden leaks. Simply turn off all taps and water using appliances, then check the meter after 15 minutes. If it moved, you have a leak.

SYSTEM IMPROVEMENTS

We continually strive to maintain and improve your water system to better serve you our customers.

Each year we work on replacing the older mains and services.

Each year we perform routine preventative maintenance on our hydrants.

Each year we perform preventative maintenance on our water meters.

We are always updating our treatment plant equipment and monitoring devices.

We are consistently staying up to date on all rules and regulations pertaining to your water system.

CLOSING

Thank you for allowing us to continue to provide your family with quality drinking water this year. We ask that all our customers help us protect our water sources, which are the heart of our community and our way of life. Please call (585) 593-3333 or e-mail me at: dana@wellsvillewater.com if you have questions. Please visit our website periodically as it is updated as new information becomes available.

Dana L. Harris
Water Treatment Plant Supervisor